

0538

**FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS**  
 (Alternative Form for Single Chamber, Completely Shop Fabricated - Vessel Only) **(A) 3130849**  
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1 Manufactured and certified by Maloney Steel Ltd. 8825 Shepard Road S.E. Calgary, Alberta T2H 1X1  
 (Name and address of manufacturer)

2 Manufactured for STARTEC REFRIGERATION SERVICES LTD. 6700 - 9 ST. N.E., CALGARY, AB. T2E 8K6  
 (Name and address of purchaser)

3 Location of installation PORTABLE  
 (Name and address)

4 Type HORIZONTAL 95-C3421-3000E N0488.2 C3421-3000 REV.1 N/A 1995  
 (Horizontal or vert. tank) (Mfg's serial No.) (CRN) (Drawing No.) (Matl. Bd. No.) (Year)

5 The chemical and physical properties of all parts meet the requirements of the material specification of the ASME BOILER AND PRESSURE VESSELS CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1  
 1992 (Year)

to A94 N/A N/A  
 Addenda (date) Code Case Nos. Special services per UG-120(d)

6 Shell: SA108B .375" .0625" 1'-6" OD 6'-0" S/S  
 Matl (Spec. No., Grade) Nominal Thk. (in.) Corr. Allow. (in.) Diameter I.D. (ft. & in.) Length (overall) (ft. & in.)

7 Seams: SEAMLESS N/A 100 N/A N/A TYPE NO. 1 SPOT 1  
 Long. (Welded, Dbl., Sngl., Lap, Butt) R.T. (Spot or Full) Effy. (%) H.T. Temp (°F) Time (hr) Girth (Welded Dbl., Sngl., Lap, Butt) R.T. (Spot, Partial, or Full) No. of Courses

8 Heads: (a) Matl. SA516-70 (b) Matl. SA516-70  
 (Spec. No. Grade) (Spec. No. Grade)

	Location (Top Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	END	.345"	.0625"	--	--	2:1 SE	--	--	--	CONCAVE
(b)	END	.345"	.0625"	--	--	2:1 SE	--	--	--	CONCAVE

If removable, bolts used (describe other fastenings) N/A  
 (Matl., Spec. No., Gr., Size, No.)

9 MAWP: 350 psi at max temp 250 F  
 Min. Design Met. Temp. -20 °F at 350 psi Hydro, pneu, or comb. test pressure 525 psi

10 Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diameter or Size	Type	Material	Nominal Thickness	Reinforcement Material	How Attached	Location
INLET	1	3"	RFWN 300#/PIPE	SA108B	.435"	INTEGRAL	WELDED	SHELL
GAS OUTLET	1	3"	RFWN 300#/PIPE	SA333-6	.300"	INTEGRAL	WELDED	SHELL
OIL OUTLET	1	2"	RFWN 300#/PIPE	SA333-6	.343"	INTEGRAL	WELDED	SHELL
LEVEL	2	1 1/2"	CPLG.	SA105	6000#	INTEGRAL	WELDED	SHELL
DRAIN/FILL/PSV	3	3/4"	TOL	SA105	6000#	INTEGRAL	WELDED	SHELL
LSL	1	1 1/2"	LONG CPLG.	SA105	6000#	INTEGRAL	WELDED	SHELL
TSHH	1	1/2"	CPLG.	SA105	6000#	INTEGRAL	WELDED	SHELL

11 Supports: Skirt NO Lugs 0 Legs 0 Other 2 SADDLES Attached WELDED TO SHELL  
 (Where and how)

12 Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: N/A  
 (Name of part, item number, Mfg's name and identifying stamp)

GAS ACCUMULATOR TAG  
 IMPACT TESTING: IMPACT TEST EXEMPTION PER UG-20(f)  
 VOLUME: 11.23 FT.<sup>3</sup> (0.32 M<sup>3</sup>)

**CERTIFICATE OF SHOP COMPLIANCE**

We certify that the statements made in this report are correct and that all details of design, material, construction and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1, "U" Certificate of Authorization No. 15742 expires MAY 5, 1998  
 Date 19/95 Co. Name Maloney Steel Ltd Signed [Signature]  
 (Manufacturer) (Representative)

**CERTIFICATE OF SHOP INSPECTION**

Vessel constructed by Maloney Steel Ltd at Calgary, Alberta, Canada  
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and / or the State or Province of Alberta and employed by Alberta Boilers Safety Association  
 have inspected the component described in the Manufacturer's Data Report on 19-12-95, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME code, Section VIII, Division 1. By signing this certificate neither the inspector nor his employer makes any warranty, expressed, or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.  
 Signed [Signature] Commissions Alberta #11  
 (Authorized Inspector) (Nat'l Bd. (incl. endorsements), State, Prov. and No.)